



Government Of West Bengal
Office Of The Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services
6, Diamond Harbour Road, Silpara, Kol-700008

Memo no.: IND/WB/FES/ 20182019/40618

Date: 21-12-2020

From:
Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

To: Jyotirmoy Public School
Dag No.-638 R.S. or L.R. No.-663, Mouza-Kalikapur, J.L. No.-95, Khatian No.-532 under Kalikapur Gram
Panchayet, P.S.-Sonarpur, Dist.-South 24 Parganas

Sub: Renewal of Fire Safety Certificate for the occupancy of a G+II storied under group of Educational Building in the name & style of "JYOTIRMOY PUBLIC SCHOOL" at the premises dag no- 638, R.S/LR no-663, Mouza-Kalikapur, Under Kalikapur 1 no Gram Panchayet, P.S Sonarpur, Dist- South 24 Parganas.

This is in reference to your application no. 0125191201200516 dated 14-11-2020 regarding the Renewal of Fire Safety Certificate for the occupancy of a G+II storied under group of Educational Building in the name & style of "JYOTIRMOY PUBLIC SCHOOL" at the premises dag no- 638, R.S/LR no-663, Mouza-Kalikapur, Under Kalikapur 1 no Gram Panchayet, P.S Sonarpur, Dist- South 24 Parganas.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.

1.The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.

2.To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.

- 3.Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them , particularly lines above false ceiling and ducts.
4. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the building.
- 5.The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
- 6.Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
- 7.Electrical main, meter and panel room shall be protected with CO2 or D.C.P. Fire Extinguishers confirming I.S. specification.
- 8.A crew of trained Fireman shall be maintained round the clock for fire safety of the building.
- 9.Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
- 10.If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
- 11.Periodical flashing of water from the Hydrant pipe lines shall be made to maintain the efficient working performance of above mentioned system.
- 12.The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
- 13.This Renewal of Fire Safety Certificate is valid for 3(Three) years and have to be renewed every three years from the date of issue of this letter.

Validity unknown

Digitally signed by Sanat
Kumar Mondal
Date: 2020.12.21 11:38:45 IST

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services